


DAVID Y. IGE
GOVERNOR OF HAWAII



BRUCE S. ANDERSON, Ph.D.
DIRECTOR OF HEALTH

STATE OF HAWAII
DEPARTMENT OF HEALTH
P. O. BOX 3378
HONOLULU, HI 96801-3378

In reply, please refer to:
File:

June 03, 2020

Yen Wen Fang
Engineering Partners, LLC
P.O. Box 4159
Hilo, HI 96720

Dear Sir/Madam:

Subject: Individual Wastewater System (IWS) for
Owner/Lessee: State of Hawaii Hawaii Health Systems Corp
Project Site: 96-1115 Kamani Street, Pahala, HI
TMK: 396023043
IWS File No.: 64432 (Septic Tank)
Old File No.: N/A

The subject wastewater plans have been reviewed by the Wastewater Branch for conformance to applicable provisions of Hawaii Administrative Rules, Title 11, Chapter 62, entitled Wastewater Systems. The IWS plan conforms to applicable provisions of Chapter 11-62.

As the professional engineer responsible for the design of the above wastewater plan, it is your responsibility to inform the owner/lessee of the property that: **a) the IWS plans must be attached to each set of permit construction plans, b) the IWS must be installed by a licensed contractor holding A, C-9, C-37, C-37a or C-43 license, c) inspected and certified by the designing engineer, d) authorized in writing by the Department of Health before use, and e) IWS approval expires in one year without concurrent active building permit.**

For new dwellings, the Department of Health will process an applicable county building permit application provided that all information submitted as part of the IWS plan and county building permit application are consistent with each other and meet applicable provisions of Chapter 11-62, HAR at the time of permit application.

For renovation projects that require abandoning the existing cesspool and/or require building modifications to the existing dwelling (require separate permit) to comply with Chapter 11-62, HAR, the new IWS and/or required modifications to the existing dwelling must be completed **prior** to applying for a County Building Permit for the project. For clarification purposes, the separate building modifications permit to the existing dwelling will be considered completed when the County Building Permit is properly closed for that work.

Should you have any questions, please feel free to contact Dane Hiromasa at 322-1963.

Sincerely,

A handwritten signature in blue ink, appearing to read "Sina Pruder".

SINA PRUDER, P.E.
Chief, Wastewater Branch